

QUESTIONS AND ANSWERS
SBI-000294
2015 ASPHALT RESURFACING PROJECT

1. It is only one layer of paving over the existing pavement or is it 2 layers? – **One Layer.**
2. What is the exact thickness of the layer to be laid? – **1 ½ inches.**
3. If it is only one layer there is no margin for correcting any defect in the level of existing surface. – **There is quantity built in to allow for spot leveling when necessary.**

Terms & Conditions

1. Does the count of the 90 days start from the Award Notice, from the signing of Contract and submission of Performance Bond or after the 10 days for initial mobilization? – **The count starts 10 days after the pre-construction meeting.**
 2. The phrasing in the bid-document around the "performance bond" is a bit confusing. It mentions "The Performance Bond and Labor and Material Bond shall each be equal to 100% of the amount of the amount of the Contract" (on page 37 of 90) and "The successful contractor must be able to submit a performance/labor material bond separate bonds each in the amount of 100% of the amount of the contract" (on page 5 of 90).....Is the Performance Bond of 100% of the contract value or as it appears to read in these sentences $3 \times 100\% = 300\%$? **The Performance Bond/Labor Material Bond are separate bonds and each is equal to 100% of the contract amount.**
 3. The Asphalt works have "TON" as a unit. Can we confirm it refers to US TON as it is nowhere described in the document? – **It is U.S Ton.**
-